

Superior Quality, Superior Service and ONLY Fuels!

Certificate of Analysis

Laboratory Number xxxxxxxx

Client:

 Any Company
 Sample Collection Date:
 06/04/07

 Date Received:
 06/07/07

 P.O Box xxxxx
 Date Analyzed:
 06/08/07

Ant Town, USA Test Package Number

Sample Taken From: Tank Capacity

Sample I.D.: Bio-diesel Type of Fuel B-100 Bio-diesel

| Test | Sample Result | Limits | Methods |
|----------------|---------------|--------------------|------------|
| Total Glycerin | 0.053 | 0.240 max (% mass) | ASTM D6584 |
| Monoglycerides | 0.136 | | |
| Diglycerides | 0.057 | | |
| Triglycerides | 0.000 | | |
| Free Glycerin | 0.006 | 0.02 max (% mass) | ASTM D6584 |

Comments: All results are within acceptable limits.